

SUPPLEMENTAL / BID BULLETIN NO. 2

Title : **Supply, Delivery and Installation of Two (2) units Uninterruptible Power Supply (UPS) with Six (6) units Power Distribution Units (PDU)**

ITB No. : **GOP/18-DSWD-027**

Date : **11 December 2018**

This Supplemental/Bid Bulletin is issued to all prospective bidders announcing changes in the procurement schedule, to wit:

Section VI. Schedule of Requirements

FROM	TO
Timeline of Schedule:	
Delivery and Installation Period: Fifteen (15) working days upon receipt of notice to proceed	Delivery and Installation Period: Forty-Five (45) working days upon receipt of notice to proceed

Section VII. Technical Specifications

FROM	TO
Surge Protection: IEC/EN60240-2 IEC/EN61000-4-5 YD/T1095-2000 YD/T944-2007	Surge Protection: IEC/EN60240-2 or IEC/EN61000-4-5 or YD/T1095-2000 or YD/T944-2007
	PDU - 12 outlet metal surge protector per PDU
	Battery Back-up Time: at least 15 minutes per 20KVA UPS
	Provided picture of PDU outlet and electrical diagram for reference.

This Bid Bulletin shall form part of the bidding documents.

Please be guided accordingly.

(original signed)
ATTY. AIMEE TORREFRANCA-NERI
Undersecretary and
Bids and Awards Committee Chairperson

Please accomplish this portion and send it to facsimile no. (02) 951-7116 or email at bacsec@dswd.gov.ph

Received from DSWD, Supplemental/Bid Bulletin No. 2 for the **Supply, Delivery and Installation of Two (2) units Uninterruptible Power Supply (UPS) with Six (6) units Power Distribution Units (PDU)** (ITB No. GOP/18-DSWD-027).

Received by : _____ Date : _____
(Signature over Printed Name)

Designation : _____

Company : _____